



$$P_w = \frac{1}{2} \rho v^2 \quad \text{EQ. 4.25}$$

where:

- ρ = Density of air
= 1.2 kg/m³ (at 1.013 bar and 20°C)
- v = Wind velocity, m/sec.

Once the uniform wind force, F_w , is determined, the restraints loads can be calculated by the method previously proposed for the uniform weight loads. Since the wind loading is modeled as a static horizontal uniform load, which may act in any direction (depending upon the local conditions) and at any time, the design engineer should consider the following:

- In how many directions should the piping system be analyzed for wind loading?
- Should the wind act on the piping system when it is in-operation (hot) or out-of-operation (cold)?

4.2.2

RELIEF VALVE DISCHARGE

When a relief valve discharges, the fluid initiates a jet force. This force must be resisted by pipe supports if the pipe is not capable of resisting the load internally.

The magnitude of the jet force is usually provided by the valve manufacturer. If this value is not known, it may be calculated fairly easily for those cases where the valve vents to the atmosphere. If the fluid discharges through a closed system, transient flow conditions may be developed which make the valve discharge force difficult to calculate.

For a relief valve venting to the atmosphere, the discharge force as shown in figure 4.10 and 4.11 can be estimated as follows:

$$F = DLF (m\dot{V} + PA) \quad \text{EQ. 4.26}$$

where:

- F = discharge force, N
- DLF = dynamic load factor. For a safe design use a value of 2.0. This may be overly conservative especially at low set pressures and where sonic flow through the valve outlet is unlikely.
- m = mass flow rate through the valve x 1.1, Kg/sec.
Where 1.1 is a safety factor accounting for the flow rate just after the valve has opened and it is flowing its maximum capacity at overpressure conditions.

- ϑ = fluid exit velocity, m/sec.
 \leq sonic velocity (ϑ_s)
- P = static gauge pressure at exit, MPa (= N/mm²)
- A = discharge flow area, mm².




Figure 4.10

Since the static pressure P and velocity ϑ at the exit of the discharge pipe are not known for the engineer when designing the discharge header, they can be estimated (approximately) by the procedure explained later in section 4.2.2.1.

The maximum velocity of a compressible fluid in pipe is limited by the velocity of propagation of a pressure wave which travels at the speed of sound in the fluid.

When the pressure drop in the downstream of the relief valve is sufficiently high, the exit velocity will reach the velocity of sound.

Further decrease in the downstream pressure will not be felt upstream because the pressure wave can not travel at a velocity higher than the sonic speed.

The maximum discharge will be obtained at the sonic speed, and any "Surplus" pressure drop in the downstream after the maximum discharge has already been reached will take place beyond the exit of the discharge pipe. This pressure will be lost in shock waves and turbulence of the jetting fluid.



Physical Properties of Gases
(Approximate values at 20°C and 1.01325 bar)

c_p = specific heat at constant pressure
 c_v = specific heat at constant volume

Name of Gas	Chemical Formula or Symbol	Approx. Molecular Weight M	Density ρ kg/m^3	Specific Gravity Relative to Air S_g	Individual Gas Constant R J/kg K	Specific Heat at Room Temperature J/kg K		Heat Capacity per Cubic Metre $\text{J/m}^3 \text{K}$		$\frac{M}{c_p}$ $\text{equiv. to } c_p/k =$
						c_p	c_v	c_p	c_v	
Acetylene (ethyne)	C_2H_2	26.0	1.0925	0.907	320	1465	1127	1601	1231	1.30
Air	—	29.0	1.2045	1.000	287	1009	721	1215	868	1.40
Ammonia	NH_3	17.0	0.7179	0.596	490	2190	1659	1572	1191	1.32
Argon	A	39.9	1.6610	1.379	208	519	311	862	517	1.67
n-Butane	C_4H_{10}	58.1	2.4897	2.067	143	1654	1490	4118	3710	1.11
Carbon dioxide	CO_2	44.0	1.8417	1.529	189	858	660	1580	1216	1.30
Carbon monoxide	CO	28.0	1.1648	0.967	297	1017	726	1185	846	1.40
Chlorine	Cl_2	70.9	2.9944	2.486	117	481	362	1440	1084	1.33
Ethane	C_2H_6	30.0	1.2635	1.049	277	1616	1325	2042	1674	1.22
Ethylene	C_2H_4	28.0	1.1744	0.975	296	1675	1373	1967	1612	1.22
Helium	He	4.0	0.1663	0.1381	2078	5234	3153	870	524	1.66
Hydrogen Chloride	HCl	36.5	1.5273	1.268	228	800	567	1222	866	1.41
Hydrogen	H_2	2.0	0.0837	0.0695	4126	14319	10155	1199	850	1.41
Hydrogen sulphide	H_2S	34.1	1.4334	1.190	243	1017	782	1458	1121	1.30
Methane	CH_4	16.0	0.6673	0.554	519	2483	1831	1657	1255	1.32
Methyl Chloride	CH_3Cl	50.5	2.1500	1.785	165	1005	838	2161	1800	1.20
Natural gas (a)	—	19.5	0.8034	0.667	426	2345	1846	1884	1483	1.27
Nitric Oxide	NO	30.0	1.2491	1.037	277	967	691	1208	863	1.40
Nitrogen	N_2	28.0	1.1648	0.967	297	1034	733	1204	854	1.41
Nitrous oxide	N_2O	44.0	1.8429	1.530	189	925	706	1705	1301	1.31
Oxygen	O_2	32.0	1.3310	1.105	260	909	649	1210	864	1.40
Propane	C_3H_8	44.1	1.8814	1.562	188	1645	1430	3095	2690	1.15
Propane propylene	C_3H_6	42.1	1.7477	1.451	198	1499	1315	2620	2298	1.14
Sulphur dioxide	SO_2	64.1	2.7270	2.264	129	645	512	1759	1396	1.26

(a) Representative values; exact characteristics require knowledge of exact constituents.

Notes. To obtain density values at 15°C, 1.01325 bar, multiply table values by 1.0174.

Where the Kelvin (K) appears in the above table it may be replaced by the degree Celsius (°C) i.e. kJ/kg K may be written kJ/kg°C.

Values of Molecular Weight, Specific Gravity, Individual Gas Constant and Specific Heat abstracted from or based on Table 24 in Mark's "Standard Handbook for Mechanical Engineers", Seventh Edition, 1966 — approximate values adapted from a number of sources.²²

Values of Densities obtained by multiplying density of dry air at 20°C, 1.01325 bar, by specific gravity of gas, i.e. $1.2045 \times S_g$. Density of air, from "Thermodynamic and Transport Properties of Fluids", Y. R. Mayhew and G. F. C. Rogers, 1972.¹⁴

Figure 4.11



When back pressure exists, it will be a very significant factor in many pressure-relief-valve applications. Unfortunately, it is sometimes neglected by designers who are unfamiliar with its effects on pressure-relief-valve operation. Back pressure is the pressure that exists on the outlet side (downstream) of the valve. Back pressure that exists prior to the opening of the valve is called "superimposed" back pressure. In conventional, unbalanced, direct spring-loaded pressure relief valves (PRV's), superimposed back pressure changes set pressure on a one to one basis.

Back pressure created by flow through the valve into downstream piping is called "built-up" back pressure.

Built-up back pressure acting on conventional spring loaded PRV's often reduces relieving capacity, causes chatter, or does both.

Normally, conventional valves can not remain fully open and allow flow properly with much more than 10% built-up back pressure. A solution to this is to redesign the configuration of the discharge piping (shorter and larger diameter) or to use balanced valves or pilot-operated valves. (see figure 4.13)

Proper selection of a PRV for use where back pressure can occur is very important. To obtain the required relief capacity and ensure stable chatter-free operation, PRV's generally best suited for this service, in order of preference are:

1. Pilot-operated safety relief valves or balanced spring-loaded valves (bellows or balanced piston type), dependent upon application.
2. Conventional spring-loaded valves.

As a rule, conventional valves should not be vented into either closed headers or long discharge pipes. Discharge pipes configurations, including the common long-radius elbow, may create even greater back pressure problems.

Built-up back pressure calculations in discharge piping design usually start at the exit and are worked out backward toward the relief valve.

The calculated built-up back pressure ' P_0 ' at the valve outlet must be less than the maximum allowable back pressure per type of valve.

$P_0 = P + \Delta P$, where ΔP is the pressuredrop in the discharge pipe. Calculations of ΔP is beyond the scope of this course.

The percentage of the built-up back pressure to the valve's set pressure:

$(P_0 : P_s) \times 100$, will determine the suitability of the valve's type for the intended service.

Figure 4.14 shows typical capacity versus back pressures for the different types of pressure relief valves.

If the built-up back pressure is too high, then make the necessary modification to the configuration of the discharge system (larger diameter and/or shorter length) or select another type of valve.

Check also the stresses in the discharge pipe, the inlet pipe and the loads on the adjacent supports.





Figure 4.13 Different types of pressure relief valves




Figure 4.14 Typical back pressure vs. capacity, at 10% overpressure, for different types of pressure relief valves.

**4.2.2.1 Determination of the pressure and velocity at the exit of the discharge pipe****Gasflow**

Step-1: Assume the exit pressure is atmospheric

$$P = 1.013 \text{ bara}$$

Step-2: Calculate the Mach number M_a :

$$M_a = \frac{4m}{\pi D^2 \times 1.013 \times 10^5} \left[\frac{zRT}{k} \right]^{\frac{1}{2}} \quad \text{EQ. 4.27}$$

where:

- M_a = the Mach no., defined as the ratio of the actual velocity and the sonic velocity
- D = inside diameter discharge pipe, m
- Z = compressibility factor
- R = individual gas constant, j/kg.k
 - = R_0/M
- R_0 = universal gas constant = 8314 j/kg.mol.k
- M = molecular weight
- k = ratio of specific heats (c_p/c_v)
- T = absolute temperature at inlet of valve, in Kelvins (= 273 + t)
- t = inlet temperature, °C

Step-3: If $M_a \leq 1.0$ then the assumed exit pressure in step-1 was correct.
Thus: $P = 1.013 \text{ bara}$.

If $M_a > 1.0$ then the assumed exit pressure was incorrect.
The correct exit pressure will be: $P = M_a \times 1.013 \text{ bara}$.

Step-4: Calculate valve relieving pressure P_r

$$P_r = P_s + \text{overpressure} + 1.013$$

where:

- P_r = relieving pressure, bara
- P_s = set pressure, barg



For 10% overpressure:

$$P_r = P_s \times 1.1 + 1.013$$

Step-5: Calculate the approximate exit temperature T_e

$$T_e = T - \frac{1}{2}(P_r - P)$$

where: T_e and T in Kelvin
 P_r and P in bara

Step-6: Calculate the sonic velocity \hat{v}_s :

$$\hat{v}_s = [kRT_e]^{1/2} \text{ m/s} \quad \text{EQ. 4.28}$$

Step-7: Calculate the exit velocity \hat{v}

If $M_a \leq 1.0$ then $\hat{v} = M_a \times \hat{v}_s$
 If $M_a > 1.0$ then $\hat{v} = \hat{v}_s$

Steamflow (Ref.: ANSI/ASME B31.1 Power Piping Code, Appendix II)

Step-1: Calculate the exit pressure P

$$P = \frac{4m}{\pi D^2 \cdot 10^3} \left(\frac{b-1}{b} \right) \left[\frac{1995 \cdot 10^{12} (h-a)}{2b-1} \right]^{1/2} \quad \text{EQ. 4.29}$$

where: P = pressure at exit of discharge pipe, bara
 D = inside diameter discharge pipe, mm
 h = specific enthalpy (total heat) at the valve inlet (at absolute set pressure and inlet temperature), kj/kg
 To be obtained from appendix 4
 a and b are listed in table 4.3

Table 4.3

Steam condition	a kj/kg	b dimensionless
Saturated, wet (< 90% Quality)	677	11
Saturated, dry (\geq 90% Quality)	1914	4.33
Superheated	1933	4.33



Step-2: Calculate the exit velocity ϑ

$$\vartheta = \left[\frac{2 \cdot 10^3 (h-a)}{2b-1} \right]^{\frac{1}{2}} \quad \text{EQ. 4.30}$$

Example 4.3:

Calculate the discharge force of a relief valve venting to atmosphere.

Given data: medium : natural gas
 inlet temperature : 15° C
 mass flow rate : 0.75 kg/s
 set pressure : 14.5 barg
 overpressure : 10%
 discharge pipe : 3" sch.40

Solution:

First calculate the pressure and velocity at the exit of discharge pipe in accordance with section 4.2.2.1, then substitute in EQ. 4.26 to obtain the discharge reaction force.

Step-1: Assume $P = 1.013$ bara

$$\text{Step-2: } M_a = \frac{4m}{\pi D^2 \times 1.013 \times 10^5} \left[\frac{zRT}{k} \right]^{\frac{1}{2}}$$

where: $m = 1.1 \times 0.75$ kg/s
 $D = 77.9 \times 10^{-3}$ m (from appendix 3)
 $Z = 1.0$ (if unknown)
 $R = 426$ j/kg.k (from fig. 4.12 if unknown)
 $k = 1.27$ (from fig. 4.12 if unknown)
 $T = 273 + 15 = 288$ K

Substituting in M_a equation gives $M_a = 0.53$

Step-3: $M_a < 1.0$ then $P = 1.013$ bara

Step-4: $P_r = P_s \times 1.1 + 1.013 = 14.5 \times 1.1 + 1.013 = 16.96$ bara

Step-5: $T_e = T - \frac{1}{2}(P_r - P) = 288 - \frac{1}{2}(16.96 - 1.013) = 280$ K

Step-6: $\vartheta_s = [kRT_e]^{\frac{1}{2}} = [1.27 \times 426 \times 280]^{\frac{1}{2}} = 389.2$ m/s



Step-7: $M_a < 1.0$ then $\vartheta = M_a \times \vartheta_s = 0.53 \times 389.2 = 206.7 \text{ m/s}$

Substitute in EQ. 4.26 to calculate the discharge reaction force.
(note: $P = 1.013 \text{ bara} = 0.0 \text{ barg} = 0.0 \text{ Mpa}$)

$$F = 2 (1.1 \times 0.75 \times 206.7 + 0.0) = 341 \text{ N}$$

Example 4.4

Calculate the discharge reaction force of a relief valve venting to atmosphere through dual outlets.

Given data:	medium	: natural gas ✓
	inlet temperature	: 43°C ✓
	mass flow rate	: 201.4 kg/s ✓
	set pressure	: 70 barg
	overpressure	: 10%
	compressibility factor	: 0.98 ✓
	molecular weight	: 18.63 ✓
	ratio of specific heats	: 1.3 ✓
	size discharge pipes	: $8'' \text{ sch.40}$ ✓

Solution

Step-1: Assume $P = 1.013 \text{ bara}$

Step-2:
$$M_a = \frac{4(\frac{1}{2}m)}{\pi D^2 \times 1.013 \times 10^5} \left[\frac{zRT}{k} \right]^{\frac{1}{2}}$$

Note: For dual outlets the massflow per discharge pipe is $\frac{1}{2}m$.

where: $m = 1.1 \times 201.4 \text{ kg/s}$
 $D = 202.7 \times 10^{-3} \text{ m}$
 $Z = 0.98$

$$R = \frac{R_0}{M} = \frac{8314}{18.63} = 446.3 \text{ J/kg.k}$$

$$k = 1.3$$

$$T = 273 + 43 = 316 \text{ K}$$

Substituting in M_a equation gives $M_a = 11.05$

Step-3: $M_a > 1.0$ then $P = M_a \times 1.013 = 11.19 \text{ bara}$



$$\text{Step-4: } P_r = P_s \times 1.1 + 1.013 = 70 \times 1.1 + 1.013 = 78.01 \text{ bara}$$

$$\text{Step-5: } T_e = T - \frac{1}{2}(P_r - P) = 316 - \frac{1}{2}(78.01 - 11.19) = 282.6 \text{ K}$$

$$\text{Step-6: } \Theta_s = [kRT_e]^{1/2} = [1.3 \times 446.3 \times 282.6]^{1/2} = 405 \text{ m/s}$$

$$\text{Step 7: } M_a > 1.0 \text{ then } \Theta = \Theta_s = 405 \text{ m/s}$$

Substitute with P and Θ in EQ. 4.26 to calculate the reaction force per outlet:

$$F = 2 \left[1.1 \times \frac{1}{2} \times 201.4 \times 405 + \left(\frac{11.19 - 1.013}{10} \right) \times \frac{\pi}{4} (202.7)^2 \right] = 155.4 \text{ kN}$$

Example 4.5

Calculate the discharge force of a relief valve venting to atmosphere.

Given data:	medium	: <u>superheated steam</u>
	inlet temperature	: 538°C
	mass flow rate	: 48 kg/s
	set pressure	: 63 barg
	size discharge pipe	: 8" sch.40

Solution

Step-1: Calculate pressure at exit of discharge pipe.

$$P = \frac{4m}{\pi D^2 \cdot 10^5} \left(\frac{b-1}{b} \right) \left[\frac{1995 \cdot 10^{12} (h-a)}{2b-1} \right]^{1/2}$$

where: $m = 1.1 \times 48 \text{ kg/s}$
 $h = 3507 \text{ kJ/kg}$ (from appendix 4) at 64 bara and 538°C
 $a = 1933 \text{ kJ/kg}$
 $b = 4.33$
 $D = 202.7 \text{ mm}$ (from appendix 3)

Substituting in P equation gives $P = 8.06 \text{ bara}$.

Step-2: Calculate velocity at exit of discharge pipe:

$$\Theta = \left[\frac{2 \times 10^3 (3507 - 1933)}{2 \times 4.33 - 1} \right]^{1/2} = 641 \text{ m/s}$$

substitute in EQ. 4.26 to calculate the discharge reaction force:



$$F = 2 \left[1.1 \times 48 \times 641 + \left(\overset{P}{\frac{8.06 - 1.013}{10}} \right) \times \overset{P_{atm}}{\frac{\pi}{4}} (202.7)^2 \right] = 113.1 \text{ kN}$$

Example 4.6

Calculate the discharge force of a relief valve to atmosphere.

Given data: medium : saturated dry steam
 mass flow rate : 1.35 kg/s
 set pressure : 11 barg
 size discharge pipe : 2" sch.40

Solution

Saturated steam at any pressure has always a definite temperature (saturation) and a definite specific enthalpy (total heat).

From appendix 4: For steam at 12 bara the specific enthalpy (total heat) is 2782.7 kJ/kg.

Step-1: Calculate the exit pressure P.

$$P = \frac{4m}{\pi D^2 \cdot 10^3} \left(\frac{b-1}{b} \right) \left[\frac{1995 \cdot 10^{12} (h-a)}{2b-1} \right]^{\frac{1}{2}}$$

where: m = 1.1 x 1.35 kg/s
 h = 2782.7 kJ/kg
 a = 1914 kJ/kg
 b = 4.33
 D = 52.5 mm

Substituting in P equation gives P = 2.51 bara.

Step-2: Calculate the exit velocity g

$$g = \left[\frac{2 \times 10^3 (2782.7 - 1914)}{2 \times 4.33 - 1} \right]^{\frac{1}{2}} = 476 \text{ m/s}$$

substitute in EQ. 4.26 to calculate the discharge reaction force:

$$F = 2 \left[1.1 \times 1.35 \times 476 + \left(\frac{2.51 - 1.013}{10} \right) \times \frac{\pi}{4} (52.5)^2 \right] = 2063 \text{ N}$$

Tabel 1.11 Gegevens homogene series aroma-componenten (25 °C)

naam	normaal kookpunt (°C)	distil- leer- punt (Pa)	actieve- coëfficiënt γ ²	relatieve vloeistof- dikte bij 20°C	specifiek gewicht
butanol	117,4	1135	43	15	16
hexanol	155,5	160	680	34	30
octanol	194,5	24	11000	85	43
aceton	56,2	30660	7,8	100	82
butan-2-on	79,6	12000	27	100	110
pentan-2-on	107	4930	100	160	160
heptan-2-on	151,5	640	1600	330	260
octan-2-on	172,9	250	6600	530	330
nonan-2-on	193	100	27000	870	650
undecan-2-on	228	25	400000	3700	1100
acetaldehyde	21	121000	4,2	110	120
propanal	48	38650	16	190	130
butanal	75	12000	61	240	200
pentanal	103	5000	250	400	240
hexanal	131	1600	1000	500	310
heptanal	153	625	4200	620	610
octanal	177	235	17000	1200	910
nonanal	191	119	71000	2300	1300
methyl acetaat	57,5	22500	24	240	200
methyl propionaat	79,7	9300	65	380	310
methyl butyraat	102,3	3330	390	500	370
methyl pentanoaat	130	973	1300	560	560
methyl hexanoaat	158	385	7100	1200	850
methyl octanoaat	193	49	13000	2800	1300

APPENDIX 4

Tabel 1.12a Gegevens verzadigde stoom

absolute druk	tempe- ratuur	specifiek volumen vloeistof (m ³ /kg)	specifiek volumen damp (m ³ /kg)	specifiek enthalpie vloeistof (kJ/kg)	specifiek enthalpie damp (kJ/kg)	specifiek enthalpie verzadigde damp (kJ/kg)	specifiek volumen verzadigde damp (m ³ /kg)	specifiek volumen verzadigde damp (m ³ /kg)
0,001	7,0	129,2	0,0077	29	2484	2513	—	—
0,002	17,5	67,0	0,0149	73	2459	2533	—	—
0,003	24,1	45,7	0,0219	101	2444	2545	—	—
0,004	29,0	34,8	0,0287	121	2433	2554	—	—
0,005	32,9	29,2	0,0355	138	2423	2561	—	—
0,006	36,0	24,5	0,0428	163	2409	2572	—	—
0,01	45,8	14,7	0,0685	197	2392	2584	—	—
0,02	60,1	7,7	0,110	231	2358	2609	—	—
0,03	69,1	5,2	0,153	269	2335	2624	—	—
0,05	81,4	3,2	0,212	340	2305	2645	—	—
0,07	90,0	2,4	0,246	377	2282	2659	—	—
0,1	99,6	1,9	0,291	417	2257	2674	1,084	1,084
0,2	120,2	0,89	0,42	505	2200	2703	1,091	1,091
0,3	133,5	0,61	0,66	561	2162	2723	1,074	1,074
0,4	143,6	0,46	0,96	604	2132	2737	1,064	1,064
0,5	151,8	0,37	1,30	640	2107	2747	1,053	1,053
0,7	165,0	0,27	1,71	697	2065	2762	1,038	1,038
1	179,9	0,19	2,24	762	2015	2777	1,028	1,028
2	212,4	0,10	3,81	908	1893	2801	1,077	1,077
3	233,8	0,067	4,7	1058	1798	2806	1,117	1,117
4	250,3	0,050	5,0	1187	1715	2802	1,252	1,252
5	264,0	0,039	5,6	1284	1641	2795	1,266	1,266
6	275,6	0,032	6,3	1313	1571	2784	1,319	1,319
8	295,0	0,023	8,5	1310	1440	2756	1,364	1,364
10	311,0	0,018	10,2	1407	1318	2726	1,451	1,451
12	324,6	0,014	12,0	1490	1197	2687	1,525	1,525
14	336,6	0,011	13,9	1559	1087	2637	1,610	1,610
16	347,3	0,009	16,0	1649	952	2581	1,713	1,713
18	357,0	0,007	18,0	1753	778	2511	1,845	1,845
20	365,7	0,0059	19,0	1827	590	2417	2,06	2,06
22	373,7	0,005	20,0	1910	390	2288	2,24	2,24
22,13	374,2	0,0032	21,0	2099	0	2099	3,30	3,30

Tabel 1.12b Soortelijke enthalpie oververhite stoom [kJ/kg]

stoomdruk [MPa]	ver- warming [°C]	temperatuur [°C]							
		200	250	300	350	400	450	500	600
0,1	99,6	2875	2974	3074	3177	3283	3394	3511	3635
0,2	120,2	2876	2976	3077	3181	3288	3401	3520	3646
0,3	133,3	2866	2967	3068	3173	3281	3395	3516	3644
0,4	143,6	2861	2962	3063	3169	3277	3392	3514	3644
0,5	151,8	2857	2958	3059	3165	3273	3388	3508	3640
0,7	165,0	2847	2948	3049	3155	3263	3378	3496	3635
1,0	179,9	2831	2932	3033	3139	3247	3362	3480	3628
2,0	212,4	—	2906	3007	3113	3221	3336	3454	3619
3,0	233,8	—	2859	2960	3066	3174	3289	3407	3610
4,0	250,3	—	—	2963	3069	3177	3292	3410	3604
5,0	264,0	—	—	—	2927	3033	3141	3256	3598
6,0	275,6	—	—	—	2866	2972	3079	3194	3590
8,0	295,0	—	—	—	2784	2890	2997	3112	3580
10	311,0	—	—	—	2698	2804	2911	3026	3568
12	324,6	—	—	—	—	2653	2759	2865	3556
14	336,8	—	—	—	—	2602	2708	2814	3544
16	347,3	—	—	—	—	2546	2652	2758	3532
18	357,0	—	—	—	—	2484	2590	2696	3520
20	365,7	—	—	—	—	2415	2524	2630	3509
22	373,7	—	—	—	—	2338	2449	2555	3497
23	—	—	—	—	—	2262	2372	2478	3485
24	—	—	—	—	—	2180	2290	2396	3473
25	—	—	—	—	—	2090	2200	2306	3461
26	—	—	—	—	—	2000	2110	2216	3449
30	—	—	—	—	—	1821	1931	2037	3430
35	—	—	—	—	—	1688	1798	1904	3411
40	—	—	—	—	—	1528	1638	1744	3392
45	—	—	—	—	—	1355	1465	1571	3373
50	—	—	—	—	—	1170	1280	1386	3354

APPENDIX 4

Stoom

Tabel 1.12c Soortelijk volume oververhite stoom [m³/kg]

stoomdruk [MPa]	massabehoudtemperatuur [°C]					
	200	250	300	400	500	600
0,1	2,17	2,4	2,6	3,1	3,6	4,12
0,2	1,98	1,20	1,31	1,55	1,78	2,01
0,3	0,72	0,80	0,9	1,1	1,2	1,3
0,4	0,54	0,6	0,65	0,77	0,89	1,01
0,5	0,43	0,47	0,52	0,62	0,71	0,9
1,0	0,21	0,23	0,26	0,31	0,35	0,4
1,5	0,15	0,15	0,17	0,2	0,24	0,27
2,0	0,11	0,11	0,13	0,15	0,18	0,2
3,0	0,09	0,09	0,1	0,12	0,14	0,16
4,0	0,07	—	—	—	—	—
5,0	—	—	—	0,06	0,07	0,09
6,0	—	—	—	0,045	0,06	0,07
8,0	—	—	—	0,04	0,05	0,06
10	—	—	—	0,02	0,03	0,04
12	—	—	—	—	0,025	0,03
15	—	—	—	—	—	0,025
18	—	—	—	—	—	0,02
20	—	—	—	—	—	0,017
22	—	—	—	—	—	0,012
23	—	—	—	—	—	0,01
24	—	—	—	—	—	0,0085
25	—	—	—	—	—	0,008
26	—	—	—	—	—	0,0075
30	—	—	—	—	—	0,006
35	—	—	—	—	—	0,005
40	—	—	—	—	—	0,0045
45	—	—	—	—	—	0,004
50	—	—	—	—	—	0,0035

Tabel 1.13 Warmte-overdrachtscoëfficiënten α [W/(m²·K)]

α	
5-15	gas (vrije convectie)
10-100	gas (gedwongen convectie)
50-1000	vloeistof (vrije convectie)
500-3000	vloeistof (gedwongen convectie)
350-580	water in rust
580-2300	water (geforceerde stroming)
11600	condenserend water
9300	condenserend ammoniak
2300	condenserend R ₁₂ , R ₂₂